

## 2018 Reporting Year

Glascote Water Quality Zone (GLA)								
Schedule 1 Parameters								
	Units	PCV	Number of samples	Number of Samples contravening PCV	% No. of samples contravening PCV	Minimum	Mean	Maximum
Colour	mg/l Pt/Co	20	80	0	0	<1.70	1.78	4
Turbidity	FTU	1	80	0	0	0.1	0.11	0.27
Odour	Dil Number	0	81	0	0	0	0	0
Taste	Dil Number	0	82	0	0	0	0	0
Sodium	mg/l	200	9	0	0	17.3	25.18	48.9
Nitrate (as NO3)	mg/l	50	9	0	0	13.1	19.39	23.5
Nitrite (as NO2)	mg/l	0.1	9	0	0	<0.01	<0.01	<0.01
Nitrate/Nitrite Ratio	mg/l	1	9	0	0	0.26	0.39	0.47
Aluminium	ug/l	-	80	0	0	5	10.58	66.2
Iron	ug/l	200	80	0	0	<4.00	11.93	39.1
Manganese	ug/l	50	80	0	0	0.9	2.33	16.7
Copper	mg/l	2	9	0	0	0.004	0.03	0.18
Fluoride	ug/l	1500	9	0	0	0.16	0.88	1.05
Arsenic	ug/l	10	9	0	0	0.5	0.74	1.1
Cadmium	ug/l	5	9	0	0	<0.10	<0.10	0.06
Chromium	ug/l	50	9	0	0	<0.70	<0.70	0.5
Nickel	ug/l	20	9	0	0	<0.80	0.88	1.3
Lead	ug/l	10	9	0	0	0.5	0.67	2
Antimony	ug/l	5	9	0	0	0.5	0.56	1
Selenium	ug/l	10	9	0	0	0.5	0.71	1.3
PAH	ug/l	0.1	9	0	0	0	0.0004	0.004
Escherichia coli	No./100ml	0	213	0	0	0	0	0
Intestinal Enterococci	cfu/100ml	0	9	0	0	0	0	0
Boron	mg/l	1	9	0	0	0.05	0.0723	0.088
Benzo(a)pyrene	ug/l	0.01	8	0	0	<0.002	<0.002	<0.002
Trihalomethanes (total)	ug/l	100	8	0	0	42.5	51.61	64.7
Bromate	ug/l	10	9	0	0	<0.50	0.54	1

Indicator Parameters								
	Units	PCV	Number of samples	Number of Samples contravening PCV	% No. of samples contravening PCV	Minimum	Mean	Maximum
pH		-	80	0	0	7	7.31	8.1
Sulphate (as SO4)	mg/l	250	9	0	0	47.7	58.51	79.7
Ammonium (as NH4)	mg/l	0.5	80	0	0	0.04	0.04	0.041
Total coliforms	No./100ml	0	213	1	0.47	0	0.0047	1
Free chlorine	mg/l	-	216	0	0	0.03	0.15	0.63
Total chlorine	mg/l	-	216	0	0	0.07	0.30	0.79
Conductivity	uS/cm	2500	80	0	0	369	521.05	679
Chloride	mg/l	250	9	0	0	53	60.44	76

\* With the exception of the Total coliform parameter all of the samples collected from this zone in 2018 complied with the Water Supply (Water Quality) (Amendment) Regulations 2018. The unsatisfactory sample was resampled and was found to comply with the regulations. Supplies to this zone are fluoridated up to a level of 1mg/l

## 2018 Reporting Year

Hayley Green Water Quality Zone (HG)								
Schedule 1 Parameters								
	Units	PCV	Number of samples	Number of Samples contravening PCV	% No. of samples contravening PCV	Minimum	Mean	Maximum
Colour	mg/l Pt/Co	20	38	0	0	<1.70	<1.70	2
Turbidity	FTU	1	38	0	0	0.1	0.11	0.59
Odour	Dil Number	0	38	0	0	0	0	0
Taste	Dil Number	0	38	0	0	0	0	0
Sodium	mg/l	200	8	0	0	19.7	25.49	30.7
Nitrate (as NO3)	mg/l	50	8	0	0	23.5	31.96	38.8
Nitrite (as NO2)	mg/l	0.1	8	0	0	<0.01	<0.01	<0.01
Nitrate/Nitrite Ratio	mg/l	1	8	0	0	0.47	0.64	0.78
Aluminium	ug/l	-	38	0	0	5	9.3	31.8
Iron	ug/l	200	38	0	0	<4.00	12.097	176
Manganese	ug/l	50	38	0	0	0.9	1.67	14.3
Copper	mg/l	2	8	0	0	0.004	0.09	0.32
Fluoride	ug/l	1500	8	0	0	0.407	0.93	1.09
Arsenic	ug/l	10	8	0	0	0.5	1.36	2.3
Cadmium	ug/l	5	8	0	0	<0.10	<0.10	0.07
Chromium	ug/l	50	8	0	0	<0.70	<0.70	0.35
Nickel	ug/l	20	8	0	0	<0.80	<0.80	1.2
Lead	ug/l	10	8	0	0	0.5	1.66	5.3
Antimony	ug/l	5	8	0	0	<0.10	<0.10	0.1
Selenium	ug/l	10	8	0	0	0.4	0.5	1
PAH	ug/l	0.1	9	0	0	0	0	0
Escherichia coli	No./100ml	0	125	0	0	0	0	0
Intestinal Enterococci	cfu/100ml	0	8	0	0	0	0	0
Boron	mg/l	1	8	0	0	0.05	0.05	0.05
Benzo(a)pyrene	ug/l	0.01	9	0	0	<0.002	<0.002	<0.002
Trihalomethanes (total)	ug/l	100	8	0	0	20.9	36.4	49.6
Bromate	ug/l	10	8	0	0	<0.50	0.86	1.3

Indicator Parameters								
	Units	PCV	Number of samples	Number of Samples contravening PCV	% No. of samples contravening PCV	Minimum	Mean	Maximum
pH		-	38	0	0	6.9	7.49	8.1
Sulphate (as SO4)	mg/l	250	8	0	0	23	32.98	41
Ammonium (as NH4)	mg/l	0.5	38	0	0	0.04	0.04	0.04
Total coliforms	No./100ml	0	125	0	0	0	0	0
Free chlorine	mg/l	-	125	0	0	0.04	0.24	0.56
Total chlorine	mg/l	-	125	0	0	0.07	0.36	0.81
Conductivity	uS/cm	2500	38	0	0	174	401.29	481
Chloride	mg/l	250	8	0	0	48	52.50	59

\* All of the samples collected from this zone in 2018 complied with the Water Supply (Water Quality) (Amendment) Regulations 2018. Supplies to this zone are fluoridated up to a level of 1mg/l